

Tender Specification

PROMASEAL® Bulkhead System

Systems shall comprise of two layers of 50mm thick, 144 kg/m³ density Mineral wool panels and shall be tightly sealed, and both faces of the fire rated panel seal and a length of 200mm of penetration shall be finish coated with 2 coats of Fire rated PROMASEAL® Bulkhead Coating. Where the opening is more than 400mm wide and 600mm in length, M.S. flats require to install to hold the Mineral Wool Panel in place and Promaseal Bulkhead Coating is require to apply even on the M.S. flats from both the side. All the installation shall be done in accordance with the manufacturers instructions to meet the integrity & insulation performance criteria in acc with BS 476Part 20. **The system will have to be supported by a valid International Test report of the complete system as per BS 476 part 20 issued by M/s.Promat International Asia Pacific Ltd.**

