

POMASTOP® Cement Penetration Sealant:

All the Shaft and services openings in fire rated walls & floors are to be properly fire stopped with 2 hrs fire rated Insulation & integrity with POMASTOP® Cement 30 mm thick. The system would involve providing and fixing of POMASTOP® Cement with 50mm thick Mineral Wool of 100 Kg density to achieve the required Insulation. Where the opening is more than 400mm wide and 600mm in length, M.S. flats require to install to hold the Mineral Wool Panel in place. Service Penetrations through walls and floors to be sealed with POMASTOP® Cement as tested to BS: 476 Part 20 & AS 1530 part 4 to maintain the required fire rating of 2hrs of the building element. Installation shall be done in accordance with the tested specification. Supply & Installation of System will done by authorized Dealer & Installer M/s.Ardor Fire & Safety Systems – Mumbai. **The system will be supported by a valid International Test report of the complete system as per BS 476 part 20 issued by M/s.Promat International Asia Pacific Ltd.**

